SIEMENS

Data sheet 6ES7134-6PA21-0CU0

Siemens EcoTech



SIMATIC ET 200SP, analog input module, AI Energy Meter RC HF, for Rogowski coils or current/voltage transformer 333 mV, with network analysis functions, suitable for BU type U0, channel diagnostics

General information	
Product type designation	AI Energy Meter RC HF
Firmware version	V8.0
● FW update possible	Yes
usable BaseUnits	BU type U0
Color code for module-specific color-coded label	CC20
Supported power supply systems	TT, TN, IT
Product function	
● Voltage measurement	Yes
— without voltage transformer	Yes
— with voltage transformer	Yes
● Current measurement	Yes; Max. 4
— without current transformer	No
— with current transformer	No
— With Rogowski coil	Yes
— With current-voltage-converter	Yes; 333 mV interface
● Energy measurement	Yes
● Frequency measurement	Yes
● Power measurement	Yes
● Active power measurement	Yes
● Reactive power measurement	Yes
● Power factor measurement	Yes
● Active factor measurement	Yes
● Reactive power compensation	Yes
● Line analysis	Yes
— Monitoring of instantaneous and half-wave values	Yes
— THD measurement for current and voltage	Yes
— Harmonics for current and voltage	Yes
— Voltage dip (DIP)	Yes
— Voltage swell	Yes
● I&M data	Yes; I&M0 to I&M3
● Isochronous mode	No
Engineering with	
● STEP 7 TIA Portal configurable/integrated from version	STEP 7 V16 or higher with HSP
● STEP 7 configurable/integrated from version	V5.5 SP3 or higher
● PROFIBUS from GSD version/GSD revision	One GSD file each, Revision 3 and 5 and higher

Subject to change without notice
© Copyright Plcally

● PROFINET from GSD version/GSD revision	V2.3
Operating mode	
● Switching between operating modes in RUN	Yes; For module version 32 I/20 Q, it is possible to dynamically switch between 25 user data variants, 23 of which are pre-defined and 2 of which can be defined by the specific user
● Cyclic measured value access	Yes
● Acyclic measured value access	Yes
● Fixed measured value sets	Yes
● Freely definable measured value sets	Yes; For cyclic and acyclic measured value access
CiR - Configuration in RUN	
Reparameterization possible in RUN	Yes
Calibration possible in RUN	Yes
Installation type/mounting	
Mounting position	any
Supply voltage	
Rated value (DC)	24 V
permissible range, lower limit (DC)	19.2 V
permissible range, upper limit (DC)	28.8 V
Input current	
Current consumption (rated value)	12.5 mA
Current consumption, max.	17 mA
Power loss	
Power loss, typ.	400 mW; 3x 230 V AC
Address area	
Address space per module	
● Inputs	256 byte
● Outputs	20 byte
Hardware configuration	
Automatic encoding	Yes
● Mechanical coding element	Yes
● Type of mechanical coding element	type C
Selection of BaseUnit for connection variants	
● 2-wire connection	BU type U0
Time of day	
Operating hours counter	
● present	Yes
Analog inputs	
Cycle time (all channels), typ.	50 ms; Time for consistent update of all measured and calculated values (cyclic und acyclic data)
Cable length	
● shielded, max.	200 m
● unshielded, max.	200 m
Analog value generation for the inputs	
Sampling frequency, max.	2 048 kHz
Interrupts/diagnostics/status information	
Alarms	
● Diagnostic alarm	Yes
● Limit value alarm	Yes
● Hardware interrupt	Yes; Monitoring of up to 16 freely selectable process values (exceeding or undershooting of value)
Diagnoses	
● Line quality	Yes
● Supply voltage	Yes
● Hardware interrupt lost	Yes
● Parameter assignment error	Yes
● Module fault	Yes
● Channel not available	Yes
● Overflow/Underflow	Yes
● Overload current	Yes

© Copyright Plcally

Diagnostics indication LED	
● Monitoring of the supply voltage (PWR-LED)	Yes
● Channel status display	Yes; green LED
● for channel diagnostics	Yes; red Fn LED
● for module diagnostics	Yes; green/red DIAG LED
Integrated Functions	
Measuring functions	
● Measuring procedure for voltage measurement	TRMS
● Measuring procedure for current measurement	TRMS
● Type of measured value acquisition	seamless
● Curve shape of voltage	Sinusoidal or distorted
● Buffering of measured variables	Yes
● Parameter length	128 byte
● Bandwidth of measured value acquisition	3.2 kHz; Harmonics: 63 / 50 Hz, 52 / 60 Hz
Measuring range	
— Frequency measurement, min.	40 Hz
— Frequency measurement, max.	70 Hz
Measuring inputs for voltage	
— Measurable line voltage between phase and neutral conductor	277 V
— Measurable line voltage between the line conductors	480 V
— Measurable line voltage between phase and neutral conductor, min.	3 V
— Measurable line voltage between phase and neutral conductor, max.	300 V
— Measurable line voltage between the line conductors, min.	6 V
— Measurable line voltage between the line conductors, max.	519 V
— Internal resistance line conductor and neutral conductor	1.5 MΩ
— Power consumption per phase	60 mW; 300 V AC
— Impulse voltage resistance 1,2/50µs	2.5 kV
— Overvoltage category	CAT II according to IEC 61010 Part 1
Measuring inputs for current (Rog. or I/U converter)	
— Measurable current at AC, max.	424 mV
— Continuous voltage, maximum permissible	2 V
— Rated value, short-time withstand voltage restricted to 1 s	30 V
— Input resistance	120 kΩ
— Zero point suppression	Yes; 0 ... 20%, referred to the nominal current
Accuracy class according to IEC 61557-12	
— Measured variable voltage	0,2
— Measured variable current	0,2
— Measured variable apparent power	0.5
— Measured variable active power	0.5
— Measured variable reactive power	1
— Measured variable power factor	0.5
— Measured variable active energy	0.5
— Measured variable reactive energy	1
— Measured variable neutral current	0,2
— Measured variable phase angle	±0.5 °; not covered by IEC 61557-12
— Measured variable frequency	0.05; only valid for the permissible voltage measuring range
— Measured variable harmonic	1
— Measured variable THDU	1
— Measured variable THDI	1
Accuracy class line analysis acc. to IEC 61000-4-30	
— Measured variable voltage	Class S
— Measured variable current	Class S
— Measured variable frequency	Class S

© Copyright Plcally

— Measured variable voltage interruption	Class S
— Measured variable voltage dip and swell	Class S
— Measured variable harmonic voltage	Class S
— Measured variable harmonic current	Class S
Potential separation	
Potential separation channels	
● between the channels	No
● between the channels and backplane bus	Yes
● Between the channels and load voltage L+	Yes; Including FE
Isolation	
Isolation tested with	Between channels and backplane bus, 24 V supply: Routine test, 1 920 V AC, 2 s; between backplane bus and 24 V supply: Type test, 707 V DC
Standards, approvals, certificates	
Ecological footprint	
● environmental product declaration	Yes
Global warming potential	
— global warming potential, (total) [CO2 eq]	9.32 kg
— global warming potential, (during production) [CO2 eq]	4.97 kg
— global warming potential, (during operation) [CO2 eq]	4.79 kg
— global warming potential, (after end of life cycle) [CO2 eq]	-0.449 kg
Ambient conditions	
Ambient temperature during operation	
● horizontal installation, min.	-30 °C
● horizontal installation, max.	60 °C
● vertical installation, min.	-30 °C
● vertical installation, max.	50 °C
Altitude during operation relating to sea level	
● Installation altitude above sea level, max.	3 000 m; Restrictions for installation altitudes > 2 000 m, see manual
Absolute humidity	
● dew point, min.	-60 °C; suitable for dry room applications
Dimensions	
Width	20 mm
Height	73 mm
Depth	58 mm
Weights	
Weight, approx.	45 g
Other	
Data for selecting a voltage transformer	
● Secondary side, max.	300 V
Classifications	

	Version	Classification
eClass	16	27-24-26-01
eClass	14	27-24-26-01
eClass	12	27-24-26-01
eClass	9.1	27-24-26-01
eClass	9	27-24-26-01
eClass	8	27-24-26-01
eClass	7.1	27-24-26-01
eClass	6	27-24-26-01
ETIM	10	EC001596
ETIM	9	EC001596
ETIM	8	EC001596
ETIM	7	EC001596
IDEA	4	3562

© Copyright Plcally

	UNSPSC	15	32-15-17-05

Approvals / Certificates

General Product Approval

Manufacturer Declaration

Miscellaneous

General Product Approval

China RoHS

For use in hazardous locations

For use in hazardous locations

FM

Maritime application

NK / Nippon Kaiji Kyokai

Maritime application

CCS (China Classification Society)

KR (Korean Register of Shipping)

Environment

last modified: 2/1/2026

© Copyright PIcally