SIEMENS

Data sheet 6ES7231-5QA30-0XB0



SIMATIC S7-1200, Analog input, SB 1231 TC, 1 AI thermocouples Type J or K

General information	
Product type designation	SB 1231, AI 1x16 bit TC
Supply voltage	
Rated value (DC)	24 V
Input current	
Current consumption, typ.	5 mA
from backplane bus 5 V DC, typ.	20 mA
Power loss	
Power loss, typ.	0.5 W
Analog inputs	
Number of analog inputs	1; Thermocouples
permissible input voltage for current input (destruction limit), max.	±35 V
permissible input voltage for voltage input (destruction limit), max.	±35 V
Technical unit for temperature measurement adjustable	Degrees Celsius/degrees Fahrenheit
Input ranges	
● Voltage	Yes
● Current	No
● Thermocouple	Yes; J, K, T, E, R & S, B, N, C, TXK/XK(L); voltage range: ±80 mV
● Resistance thermometer	No
● Resistance	No
Input ranges (rated values), voltages	
● -80 mV to +80 mV	Yes
— Input resistance (-80 mV to +80 mV)	≥1 MOhm
Input ranges (rated values), thermocouples	
● Type J	Yes
— Input resistance (type J)	1 200 °C
● Type K	Yes
— Input resistance (Type K)	1 372 °C
Thermocouple (TC)	
Temperature compensation	
— Parameterizable	No
Analog outputs	
Number of analog outputs	0
Cable length	

© Copyright Plcally

● shielded, max.	100 m; shielded, twisted pair
Analog value generation for the inputs	
Measurement principle	integrating
Integration and conversion time/resolution per channel	
● Resolution with overrange (bit including sign), max.	15 bit; + sign
● Integration time, parameterizable	No
● Interference voltage suppression for interference frequency f1 in Hz	85 dB at 10 / 50 / 60 / 400 Hz
Smoothing of measured values	
● Parameterizable	Yes
Errors/accuracies	
Temperature error (relative to input range), (+/-)	25 °C ±0.1%, to 55 °C ±0.2% total measurement range
Repeat accuracy in steady state at 25 °C (relative to output range), (+/-)	0.5 %
Interference voltage suppression for f = n x (f1 +/- 1 %), f1 = interference frequency	
● Common mode interference, min.	120 dB
Interrupts/diagnostics/status information	
Alarms	Yes
Diagnostics function	Yes; Can be read out
Alarms	
● Diagnostic alarm	Yes
Diagnoses	
● Wire break	Yes
Diagnostics indication LED	
● for status of the inputs	Yes
● for maintenance	Yes
Standards, approvals, certificates	
CE mark	Yes
CSA approval	Yes
UL approval	Yes
cULus	Yes
FM approval	Yes
RCM (formerly C-TICK)	Yes
KC approval	Yes
Marine approval	Yes
Ambient conditions	
Free fall	
● Fall height, max.	0.3 m; five times, in product package
Ambient temperature during operation	
● min.	-20 °C
● max.	60 °C
● horizontal installation, min.	-20 °C
● horizontal installation, max.	60 °C
● vertical installation, min.	-20 °C
● vertical installation, max.	50 °C
Ambient temperature during storage/transportation	
● min.	-40 °C
● max.	70 °C
Air pressure acc. to IEC 60068-2-13	
● Operation, min.	795 hPa
● Operation, max.	1 080 hPa
● Storage/transport, min.	660 hPa
● Storage/transport, max.	1 080 hPa
Relative humidity	
● Operation at 25 °C without condensation, max.	95 %
Pollutant concentrations	
● SO2 at RH < 60% without condensation	S02: < 0.5 ppm; H2S: < 0.1 ppm; RH < 60 % condensation-free
Connection method	
required front connector	Yes

© Copyright Plcally

Mechanics/material	
Enclosure material (front)	
● Plastic	Yes
Dimensions	
Width	38 mm
Height	62 mm
Depth	21 mm
Weights	
Weight, approx.	35 g

Classifications

	Version	Classification
eClass	16	27-24-22-01
eClass	14	27-24-22-01
eClass	12	27-24-22-01
eClass	9.1	27-24-22-01
eClass	9	27-24-22-01
eClass	8	27-24-22-01
eClass	7.1	27-24-22-01
eClass	6	27-24-22-01
ETIM	10	EC001420
ETIM	9	EC001420
ETIM	8	EC001420
ETIM	7	EC001420
IDEA	4	3562
UNSPSC	15	32-15-17-05

Approvals / Certificates

General Product Approval

Manufacturer Declaration

General Product Approval | **For use in hazardous locations**

CCC-Ex | FM

For use in hazardous locations | **Maritime application**

Type Examination Certificate | Miscellaneous | CCC-Ex

Maritime application

NK / Nippon Kaiji Kyokai

Maritime application | **Environment**

© Copyright Plcally

CCS (China Classification Society) KR (Korean Register of Shipping)

last modified:	5/16/2025

© Copyright Plcally