SIEMENS

Data sheet 7KM2111-1BA00-3AA0

SENTRON, measuring device, 7KM PAC3200, LCD, L-L: 500 V, L-N: 289 V, 5 A, 3-phase, Modbus TCP, optional Modbus RTU / PROFINET / PROFIBUS, apparent/ active/reactive energy, class 0.5 acc. to IEC61557-12 or class 0.5s acc. to IEC62053-22, ext-low volt. pwr sup. unit DC, DC 22 ... 65 V +/- 10%, screw terminals

Model	
product brand name	SENTRON
Measurements	
measuring procedure	
● for voltage measurement	RMS
● for current measurement	TRMS
type of measured value detection	complete
voltage curve	Sinusoidal or distorted
measurable line frequency	
● initial value	45 Hz
● full-scale value	65 Hz
operating mode for measured value detection automatic line frequency detection	Yes
operating mode for measured value detection	
● set at 50 Hz	No
● set to 60 Hz	No
Supply voltage	
design of the power supply	Extra-low voltage power supply unit
type of voltage of the supply voltage	DC
supply voltage at DC	22 ... 65 V
Degree of protection protection class	
protection class IP on the front	IP65
operating resource protection class when installed	II
Suitability	
suitability for operation	Installation in stationary panels in closed rooms
Product Functions	
product function	
● voltage measurement	Yes
● current measurement	Yes
● active power measurement	Yes
● reactive power measurement	Yes
● frequency measurement	Yes
Display and operation	
design of the display	LCD
height of the display	54 mm
width of the display	72 mm
color of the background of the display	white
national language on the display screen is supported	ger, en, fr, spa, ita, por, tur, chi
number of keys	4
Communication	
transfer rate minimum	10 000 kbit/s
transfer rate maximum	10 000 kbit/s
number of interfaces according to Fast Ethernet	1
protocol at the Ethernet interface is supported	MODBUS TCP
Fault limits	
reference condition for metering accuracy	according to IEC62053-22 and IEC62053-23
formula for relative total measurement inaccuracy	

Subject to change without notice
© Copyright Plcally

● for measured variable voltage	+/- 0.3 %
● for measured variable current	+/- 0.2 %
● for measured variable output factor	+/- 0,5 %
● for measured variable active energy	Cl. 0.5 acc. to... IEC62053-22
● for measured variable reactive energy	Class 2 according to IEC61557-12 and/or IEC62053-23
Inputs Outputs	
number of digital inputs	1
number of digital outputs	1
digital output version	switching or pulse output function
operating voltage as output voltage at DC maximum permissible	30 V
output current	
● at digital output with signal <0> maximum	0.2 mA
● at digital output for signal <1> maximum	27 mA
internal resistance at the digital outputs	55 Ω
standard for pulse emitter	according to IEC62053-31
pulse duration	
● initial value	30 ms
● full-scale value	500 ms
adjustable time period minimum	10 ms
switching frequency at digital output maximum	17 Hz
property of the output short-circuit proof	Yes
measuring category for digital signals	CATII
Measuring inputs	
measurable supply voltage between (PE)N and L at AC maximum rated value	289 V
measurable supply voltage between (PE)N and L at AC	
● minimum	40 V
● maximum	346 V
measurable supply voltage between the line conductors at AC maximum rated value	500 V
measurable supply voltage between the line conductors at AC	
● minimum	70 V
● maximum	600 V
line conductors and neutral conductors internal resistance for voltage measurement	1.05 MΩ
measuring category for voltage measurement	CAT III
measurable current	
● 1 at AC rated value	1 A
● 2 at AC rated value	5 A
relative measurable current at AC	
● minimum	10 %
● maximum	120 %
current measuring range extension with external current transformers	Yes
zero point suppression for current measurement	0.1 ... 10 %
measuring category for current measurement	CATIII
Connections	
type of connectable conductor cross-sections	
● at the measurement inputs for voltage solid	1x (0.5 ... 4 mm²), 2x (0.5 ... 2.5 mm²)
● at the measurement inputs for voltage finely stranded with core end processing	1x (0.5 ... 2.5 mm²), 2x (0.5 ... 1.5 mm²)
● at the measurement inputs for voltage for AWG cables solid	2x 20 to 14
● at the measurement inputs for current solid	1x (0.5 ... 4 mm²), 2x (0.5 ... 2.5 mm²)
● at the measurement inputs for current finely stranded with core end processing	1x (0.5 ... 2.5 mm²), 2x (0.5 ... 1.5 mm²)
● at the measurement inputs for current for AWG cables solid	2x 20 to 14
type of electrical connection	
● at the measurement inputs for voltage	screw-type terminals

© Copyright Plcally

Mechanical Design	
size of Power Monitoring Device	size 96
height	96 mm
width	96 mm
depth	56 mm
installation depth	51 mm
mounting position	vertical
Environmental conditions	
ambient temperature during operation	
● minimum	-10 °C
● maximum	55 °C
ambient temperature during storage	
● minimum	-25 °C
● maximum	70 °C
relative humidity at 25 °C without condensation during operation maximum	95 %
installation altitude at height above sea level maximum	2 000 m
Certificates	
certificate of suitability as EC Declaration of Conformity	IEC 61010-1: 2001 (2nd Ed.) with Corr. 1, EN 61010-1: 2001 (2nd Ed.) and DIN EN 61010-1:2002 with "Berichtigung 1"

Approvals Certificates

General Product Approval				EMV
Metrological Approval			Confirmation	

other		Environment		
Confirmation		Environmental Con-firmations	Environmental Con-firmations	

Further information

Information on the packaging
https://www.plcally.com/?s=7KM2111-1BA00-3AA0

Information for data generation and storage
https://www.plcally.com/?s=7KM2111-1BA00-3AA0

Information- and Downloadcenter (catalogues, leaflets,...)
https://www.plcally.com/?s=7KM2111-1BA00-3AA0

Industry Mall (Online ordering system)
https://www.plcally.com/?s=7KM2111-1BA00-3AA0

Service&Support (Manuals, Certificates, Characteristics, FAQs,...)
https://www.plcally.com/?s=7KM2111-1BA00-3AA0

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, ...)
https://www.plcally.com/?s=7KM2111-1BA00-3AA0

CAx-Online-Generator
https://www.plcally.com/?s=7KM2111-1BA00-3AA0

Tender specifications
https://www.plcally.com/?s=7KM2111-1BA00-3AA0

last modified: 4/25/2026

© Copyright Plcally